

ADDITIONAL SERVICE REQUIREMENTS PER CITY OF AMORY ELECTRIC DEPARTMENT

- 1. NEUTRAL CONDUCTOR SHALL BE SAME SIZE AS HOT LEG CONDUCTORS AND BE EITHER WHITE OR MARKED ON BOTH ENDS WITH WHITE TAPE**
- 2. CONDUIT RISER THAT EXTENDS ABOVE THE ROOF LINE SHALL BE MINIMUM 2 INCH ID CONDUIT AND BE EITHER RIGID GALVANIZED OR INTERMEDIATE METAL CONDUIT**
- 3. ACORN CLAMP MUST BE USED TO CONNECT THE GROUND CONDUCTOR TO THE GROUND ROD**
- 4. UNDERGROUND SERVICE REQUIRES SCHEDULE 80 PVC OR RIGID GALVANIZED FROM METER SOCKET TO DEPTH BELOW GROUND SPECIFIED BY UTILITY DEPARTMENT WITH ONE 90 DEGREE ELBOW AT BOTTOM OF CONDUIT. NO 45 DEGREE BENDS ALLOWED.**

THIS IS NOT AN ALL INCLUSIVE LIST OF REQUIREMENTS FOR SERVICE INSTALLATION. REFERENCE THE CURRENT ADOPTED *NEC* FOR ADDITIONAL REQUIREMENTS.

THIS LIST IS SUBJECT TO CHANGE AT ANY TIME. IT IS THE RESPONSIBILITY OF THE *LICENSED ELECTRICIAN* TO ENQUIRE IF ANY REQUIREMENTS HAVE CHANGED.